

Message

From: Paul Hlavinka -MDE- [paul.hlavinka@maryland.gov]
Sent: 10/23/2020 3:51:15 PM
To: Ottinger, Elizabeth [Ottinger.Elizabeth@epa.gov]
Subject: Hardness Value

To answer your question "Did MDE use the default of 100 mg/l to come up with the benchmark values in the appendix?" The answer is yes, that is the default.

--

Email Updates

[Click here](#) to subscribe to an email newsletter providing updates regarding MDE's general discharge permits.



Paul Hlavinka
Chief, Industrial Stormwater Permits Division
Water and Science Administration
Maryland Department of the Environment
1800 Washington Boulevard
Baltimore, Maryland 21230
paul.hlavinka@maryland.gov
410-537-3631 (O)
[Website](#) | [Facebook](#) | [Twitter](#)

[Click here](#) to complete a three question customer experience survey.

[Click here](#) to complete a three question customer experience survey.